

TEST REPORT

DATE: 11-02-2022

TEST NUMBER: 0405158

CLIENT	Catalina Home
--------	---------------

TEST CONDUCTED	ASTM D1335 Standard Test Method for Tuft Bind of Pile Yarn Floor Coverings
----------------	--



PRODUCT NAME	Eternal Flow Backing
DESCRIPTION OF PRODUCT TESTED	Turf

GENERAL PRINCIPLE

This test method is designed to measure the force required to pull a tuft completely out of a pile floor covering. It is applicable to both cut and looped pile construction.

TEST RESULTS

15.7	13.7	22.3	13.3	17.5
16.2	19.7	20.7	17.2	16.9
16.7	17.6	15.9	15.3	11.4

AVERAGE TUFT BIND	16.7 Lbs.
-------------------	-----------

APPROVED BY: *Larry Atkinson*



This facility is accredited by the National Voluntary Laboratory Accreditation Program for the specific scope of accreditation under Lab Code 100297. This accreditation does not constitute an endorsement, certification, or approval by NIST or any agency of the United States Government for the product tested. This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical or similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.